

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/23/2011
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155474		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 09/16/2011	
NAME OF PROVIDER OR SUPPLIER BREMEN HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 316 WOODIES LANE BREMEN, IN 46506			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Comparative Federal Monitoring Survey conducted on 07/21/11 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 09/16/11</p> <p>Facility Number: 000506 Provider Number: 155474 AIM Number: 100266530</p> <p>Surveyor: Richard D. Schade, Life Safety Code Specialist.</p> <p>At this PSR survey, Bremen Health Care Center was found in compliance with the Requirements for Participation in Medicare/Medicaid, 42 CFR, Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The original building was constructed in 1984 with the 300 wing added in 1994 and the 100 East and Lounge in 1995. The facility has a fire alarm system with smoke detection in the corridors, resident sleeping rooms and spaces open to the corridors. The facility has a capacity of 97 beds and had a census of 95 at the time of the survey.</p> <p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 09/22/11.</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.